



COMBINED ECONOMIC AND EMISSION DISPATCH USING EVOLUTIONARY ALGORITHMS-A CASE STUDY

A. Lakshmi Devi and O. Vamsi Krishna

Department of Electrical and Electronic Engineering, SVUCE, Tirupati, A. P., India

E-mail: energylak@yahoo.co.in

ABSTRACT

An efficient and optimum economic operation of electric power generation systems has always occupied an important position in the electric power industry. This involves allocation of the total load between the available generating units in such a way that the total cost of operation is kept at a minimum. In recent years this problem has taken a suitable twist as the public has become increasingly concerned with environmental matters, so that economic dispatch now includes the dispatch of systems to minimize pollutants, as well as to achieve minimum cost. This paper proposes a lambda based approach for solving the Combined Economic and Emission Dispatch (CEED) problem using Genetic Algorithm (GA) and Particle Swarm Optimization (PSO) methodologies considering the power limits of the generator. The purpose of Combined Economic and Emission Dispatch (CEED) is to minimize both the operating fuel cost and emission level simultaneously while satisfying load demand and operational constraints. This multi-objective CEED problem is converted into a single objective function using a modified price penalty factor approach.

Keywords: combined economic and emission dispatch, CEED, genetic algorithm, population, particle swarm optimization, particles.

INTRODUCTION

In recent years the economic dispatch problem has taken a suitable twist as the public has become increasingly concerned with environmental matters. The absolute minimum cost is not any more the only criterion to be met in the electric power generation and dispatching problems. The generation of electricity from the fossil fuel releases several contaminants, such as sulfur oxides (SO₂), and oxides of nitrogen (NO_x) into the atmosphere. These gaseous pollutants cause harmful effects on human beings as well as on plants and animals. The Clean Air Act Amendments of 1990 (CAAA) mandates that the electric utility industry should reduce its SO₂ emission by 10 million ton/year and the NO_x by 2 million ton/year from the 1980 level [4].

The limiting levels of emissions over a schedule horizon represent additional operational constraints that are to be satisfied when finding the optimal solution for the economic dispatch problem. The characteristics of emissions of different pollutants are different and are usually highly non-linear. This increases the complexity and non-monotonicity of the emission constrained economic dispatch problem. This work focuses on emission of nitrogen oxides (NO_x) only, because its control is a significant issue at the global level.

PROBLEM FORMULATION

The economic dispatch and emission dispatch are considerably different. The economic dispatch deals with only minimizing the total fuel cost (operating cost) of the system violating the emission constraint. On the other hand emission dispatch deals with only minimizing the total emission of NO_x from the system violating the economic constraints. Therefore it is necessary to find out an operating point, that strikes a balance between cost and emission. This is achieved by combined economic and emission dispatch (CEED). The multi-objective combined

Economic and emission dispatch problem is converted into single optimization problem by introducing price penalty factor h [7]:

$$\text{Minimize } \Phi = F + h * E \quad (\text{Rs./hr}) \quad (1a)$$

Subject to the constraints:

$$\sum_{i=1}^n P_i = P_D + P_{loss} \quad (1b)$$

and

$$\text{Max } (P_{i,\min}) \leq P_i \leq \text{Min } (P_{i,\max}) \quad (1c)$$

The price penalty factor h blends the emission with the normal fuel costs and Φ is the total operating cost of the system (*i.e.*, the cost of fuel + the implied cost of emission).

Once the value of price penalty factor is determined, the problem reduces to a simple economic dispatch problem. By proper scheduling of generating units, comparative reduction is achieved in both total fuel cost and NO_x emission.

COMBINED ECONOMIC AND EMISSION DISPATCH USING GENETIC ALGORITHM

Genetic string representation

Before applying a GA to any task, a computer compatible representation or encoding must be developed. These representations are referred to as chromosome. The most common representation is a binary string, where sections of the string represent encoding parameters of the solution. The number of bits assigned to a given parameter will determine the numerical accuracy.



Encoding and decoding

Implementation of a problem in a GA starts from the parameter encoding (i.e., the representation of the problem). The encoding must be carefully designed to utilize the GA's ability to efficiently transfer information between chromosome strings and objective function of problem. The proposed approach uses the equal system λ (equal system incremental cost) criterion as its basis. The only encoded parameter is the normalized system incremental cost, λ_{nm} . The advantage of using system λ instead of units' output as the encoded parameter is that the number of bits of chromosome will be entirely independent of the number of units. This is particularly attractive in large-scale systems.

The resolution of the solution depends upon the number of bits used to represent λ_{nm} . In other words, the more encoding bits there are, the higher the resolution. However, on the other hand, the more encoding bits there are, the slower the convergence. In this paper, 12 bits are used to represent λ_{nm} . Figure-1 shows the encoding scheme of λ_{nm} .




Figure-1. The encoding scheme of λ_{nm}

Evaluation of a chromosome is accomplished by decoding the encoded chromosome string and computing the chromosome's fitness value using the decoded parameter. The decoding of λ_{nm} can be expressed as:

$$\lambda_{nm} = \sum_{i=1}^{12} (d_i \times 2^{-i}) \quad d_i \in \{0,1\} \quad (2)$$

The relationship between the actual system incremental cost, $\lambda_{f,e}$, and the normalized system incremental cost, λ_{nm} , is:

$$\lambda_{f,e} = \lambda_{min} + \lambda_{nm}(\lambda_{max} - \lambda_{min}) \quad (3)$$

Where, λ_{min} and λ_{max} are the minimum and maximum values of system incremental cost.

Generation output

For a given $\lambda_{f,e}$ the generation output of each unit can be determined iteratively by solving the equation,

$$P_i = \frac{1 - \frac{(b_i + h_m \beta_i)}{\lambda_{f,e}} - \sum_{\substack{j=1 \\ j \neq i}}^n 2B_{ij} P_j}{\frac{(2a_i + 2h_m \alpha_i)}{\lambda_{f,e}} + 2B_{ii}} \quad (4)$$

Subjected to the P_i limits.

The fitness function

Implementation of a problem in a genetic algorithm is realized within the fitness function. Since the proposed approach uses the equal incremental cost criterion as its basis, the constraint equation can be rewritten as:

$$\varepsilon = \left| \sum_{i=1}^n P_i - P_D - P_{loss} \right| \quad (5)$$

Then, the converging rule is when ε (error) decreases to within a specified tolerance. In order to emphasize the "best" chromosomes and speed up convergence of the iteration procedure, fitness is normalized into the range between 0 and 1. The fitness function adopted is:

$$FIT = \frac{1}{1 + k \left(\frac{\varepsilon}{P_D} \right)} \quad (6)$$

Where, k is a scaling constant ($k = 50$ in this study).

Genetic operation

Genetic operators are the stochastic transition rules employed by GA. These operators are applied on each string during each generation to generate a new and improved population from the old one. A simple GA consists of three basic operators: Elitism, Crossover and Mutation.

Elitism

The copying of best population to next population is called "Elitism". If the probability is high, then the convergence rate increases. But it will not be too high to get the good result. The implementation of elitism is done by choosing the best population from the previous generation. The population is chosen as 60 so initially the performance index for all the population is calculated and then the chromosomes are arranged in the descending order according to their fitness value. Then the first 15% of the population is copied to the next generation.

Crossover

Uniform crossover technique is adapted in this problem. For carrying out the crossover, there is a need to identify the parents. The parent selection is done by using the Roulette wheel technique.

This parent selection is to be repeated two times to get the two parents for crossover. After selecting the parents, a random number is generated between 0 and 1, and then this random number is compared with the crossover probability (P_c). If it is less than P_c , crossover is performed. If it is greater than P_c , Par1 and Par2 are directly selected as Chld1 and Chld2. The crossover probability is taken as 0.70.



Mutation

Mutation is the process of random modification of the value of a string position with a small probability. It is not a primary operator but it ensures that the probability of searching any region in the problem space is never zero and prevents complete loss of genetic material through reproduction and crossover. The mutation probability is taken as 0.01.

Algorithm

The algorithm for solving the combined economic and emission dispatch problem using Genetic Algorithm method is given below:

1. Read generator data, emission data, P limits, B-coefficients, power demand and GA parameters.
2. Compute the modified price penalty factor h_m as per steps discussed above.
3. Generate initial population of chromosome of binary bits using random generation technique.
4. Set the iteration count =1.
5. Set chromosome count =1.
6. Decode the chromosomes of the population and determine normalized system incremental cost, λ_{nm} .
7. Calculate the actual system incremental cost, λ_{fe} using eqn.(3).
8. Calculate the generation output of all the units for each chromosome from its λ_{fe} value using eqn. (4) and enforce P_i limits.
9. Calculate transmission losses using B-coefficient equation and compute the error using eqn. (5).
10. Calculate the fitness value of the chromosome, using the eqn. (6).
11. Repeat the procedure from step no. 6 until chromosome count > population size.
12. Sort the chromosomes and all their related data in the descending order of fitness.
13. Check if the error (1) is less than ϵ . if yes, go to 20.
14. Copy the P_e % chromosomes of old population to new population starting from the best ones from the top.
15. Perform crossover on selected parents and generate new child chromosomes, repeat it to get required number of chromosomes.
16. Add all the generated child chromosomes to new population.
17. Perform mutation on all chromosomes.
18. Replace old population with new population.
19. Increment iteration count. If iteration count < max. Iteration, go to 5; else print the message "problem not converged in maximum number of iterations".
20. Calculate the total fuel cost, total emission release, emission cost etc. Print the result.

COMBINED ECONOMIC AND EMISSION DISPATCH USING PARTICLE SWARM OPTIMIZATION

Overview of Particle Swarm Optimization (PSO)

Like evolutionary algorithms, PSO technique conducts search using a population of particles, corresponding to individuals. Each particle represents a candidate solution to the problem at hand. In a PSO system, particle changes their positions by flying around in a multi-dimensional search space until computational limitations are exceeded. In Particle Swarm Optimization, a particle is defined as a moving point in hyperspace. For each particle, at the current time step, a record is kept of the position, velocity, and the best position found in the search space so far.

Let x and v denote a particle coordinates (position) and its corresponding flight speed (velocity) in a search space, respectively. The best previous position of a particle is recorded and represented as $pbest$. The index of the best particle among all the particles in the group is represented as $gbest$. Each particle knows the best value so far ($pbest$) and best value in the group ($gbest$). The particle tries to modify its position using the current velocity and the distance from $pbest$ and $gbest$. At last, the modified velocity and position of each particle can be calculated as using the following formulas:

$$v_i^{k+1} = w * v_i^k + c_1 * rand_1 * (pbest_i - x_i) + c_2 * rand_2 * (gbest_i - x_i) \quad (7a)$$

$$x_i^{k+1} = x_i + v_i^{k+1} \quad (7b)$$

where

v_i^k : velocity of particle i at iteration k
 w : inertia weight factor
 c_1, c_2 : learning factor
 $rand_1, rand_2$: random number between 0 and 1
 x_i^k : position of particle i at iteration k

It is worth mentioning that the second term in eqn. (7a) represents the cognitive part of PSO where the particle changes its velocity based on its own thinking and memory. The third term represents the social part of PSO where the particle changes its velocity based on the social-psychological adaptive of knowledge.

The constants c_1 and c_2 pull each particle towards $pbest$ and $gbest$ positions. Low values allow particles to roam far from the target regions before being tugged back. On the other hand, high values result in abrupt movement towards, or past, target regions. Hence, the acceleration constants c_1 and c_2 are often set to be 2.0 according to past experiences. Suitable selection of inertia weight ' w ' provides a balance between global and local explorations, thus requiring less iteration on average to find a sufficiently optimal solution. As originally developed, w often decreases linearly from about 0.9 to 0.4 during a run. In general, the inertia weight w is set according to the following equation,



$$w = w_{\max} - \frac{(w_{\max} - w_{\min}) \times iter}{iter_{\max}} \quad (8)$$

where

iter : current iteration number
 iter_{max} : maximum number of iterations

In the iteration process the particle velocity is limited by some maximum value v_i^{max} . The parameter v_i^{max} determines the resolution, or fitness, with which regions are to be searched between the present position and the target position. This limit enhances the local exploration of the problem space and it realistically simulates the incremental changes of human learning. If v_i^{max} is too high, particles might fly past good solutions. If v_i^{max} is too small, particles may not explore sufficiently beyond local solutions. In many experiences with PSO, v_i^{max} was often set at 10-20% of the dynamic range of the variable on each dimension.

Constriction factor approach

This factor may help in sure convergence. A low value of k facilitates rapid convergence and little exploration - high values gives slow convergence and much exploration. The constriction factor was proposed by the mathematician Maurice Clerc. He has studied about the convergence condition of particle swarm system by means of second order differential equations. In the constriction model k is set as a function of c_1 and c_2 , so that convergence is ensured- even without v_i^{max} . The constriction factor in the velocity update equation is represented by,

$$k = \frac{2}{\left| 2 - \varphi - \sqrt{\varphi^2 - 4\varphi} \right|} \quad (9)$$

where $\varphi = c_1 + c_2$ and $\varphi > 4$

By including the constriction factor, the modified velocity and position of each particle can be calculated as using the following formulas:

$$V_{ik}^{k+1} = k * (w * v_i^k + c_1 * rand_1 * (pbest_i - x_i) + c_2 * rand_2 * (gbest_i - x_i)) \quad (10a)$$

$$X_{ik}^{k+1} = x_i + v_i^{k+1} \quad (10b)$$

Application of PSO to economic and emission dispatch problem

In order to solve a constrained economic and emission dispatch problem, a PSO algorithm was developed to obtain efficiently a high-quality solution within practical power system operation. The PSO algorithm was utilized mainly to determine the optimal lambda and hence power generation of each unit that was submitted to operation at the specific period, thus minimizing the total emission and generation cost.

Representation of individual

For an efficient evolutionary method, the representation of chromosome strings of the problem parameter set is important. The proposed approach uses the equal system incremental cost ($\lambda_{f,e}$) as individual (particles) of PSO. Each individual within the population represents a candidate solution for solving the emission and economic dispatch problem. The advantage of using system Lambda instead of generator units' output is that, it makes the problem independent of the number of the generator units and also number of iterations for convergence decreases drastically. This is particularly attractive in large-scale systems.

Evaluation function

The evaluation function must be defined (it is called fitness function in GA) for evaluating the fitness of each individual in the population. In order to emphasize the "best" chromosome and speed up convergence of the iteration procedure, the evaluation value is normalized into the range between 0 and 1. The evaluation function is adopted as

$$f = \frac{1}{1 + k \left(\frac{\sum_{i=1}^n P_i - P_D - P_{loss}}{P_D} \right)} \quad (11)$$

Where, k is a scaling constant ($k = 50$ in this study).

In order to limit the evaluation value of each individual of the population within a feasible range, before estimating the evaluation value of an individual, the generation power output must satisfy the entire P_i limits.

Comparison between genetic algorithm and PSO

Most of evolutionary techniques have the following procedure:

1. Random generation of an initial population.
2. Calculating of a fitness value for each subject. It will directly depend on the distance to the optimum.
3. Reproduction of the population based on fitness values.
4. If requirement are met, then stop. Otherwise go back to 2.

From the procedure, it is understood that PSO shares many common points with GA. Both algorithms start with a group of a randomly generated population, both have fitness values to evaluate the population. Both update the population and search for the optimum with random techniques. Both systems do not guarantee success.

However, PSO does not have genetic operators like crossover and mutation. Particles update themselves with the internal velocity. They also have memory, which is important to the algorithm.



Compared with genetic algorithms (GAs), the information sharing mechanism in PSO is significantly different. In GAs, chromosomes share information with each other. So the whole population moves like a one group towards an optimal area. In PSO, only *gbest* (or *lbest*) gives out the information to others. It is a one-way information sharing mechanism. The evolution only looks for the best solution. Compared with GA, all the particles tend to converge to the best solution quickly even in the local version in most cases.

Algorithm

The algorithm for solving the combined emission and economic dispatch problem using PSO method is given below:

1. Read generator data, emission data, P limits, B-coefficients and power demand, population size and number of iterations.
2. Compute the modified price penalty factor h_m as per steps discussed above.
3. The minimum and maximum limits of Lambda are computed using the incremental cost ($\lambda_{f,e}$) equation. The particles are generated by selecting a value with a uniform probability over the search space ($\lambda_{f,e}^{\min}$, $\lambda_{f,e}^{\max}$).
4. The initial velocities of all particles are generated randomly between the velocity limits ($-Vmax$, $Vmax$). The maximum velocity is given by

$$V_{\max} = \frac{\lambda_{f,e}^{\max} - \lambda_{f,e}^{\min}}{N_a} \quad (12)$$

Where, N_a is number of intervals (10 are taken in this work).

5. Calculate the generation output of all the units for each particle from its $\lambda_{f,e}$ value using equation

$$P_i = \frac{1 - \frac{(b_i + h_m \beta_i)}{\lambda_{f,e}} - \sum_{\substack{j=1 \\ j \neq i}}^n 2B_{ij} P_j}{\frac{(2a_i + 2h_m \alpha_i)}{\lambda_{f,e}} + 2B_{ii}} \quad (13)$$

and enforce P_i limits.

6. Calculate transmission losses using B-coefficient equation.
7. Calculate the evaluation value of each individual in the population using the evaluation function given by eqn.(11). These values are set as *pbest* value of the particles.
8. Compare each individual's evaluation value with its *pbest*. The best evaluation value among the *pbest* is denoted as *gbest*.
9. Using the *gbest* and the individual best (*pbest*) of each particle, new velocities are calculated using the eqn. (10a). If a particle violates the velocity limits, set its

velocity equal to the limit (i.e. If $v_i^{k+1} > Vmax$, then $v_i^{k+1} = Vmax$ and if $v_i^{k+1} < -Vmax$, then $v_i^{k+1} = -Vmax$).

10. Based on the updated velocities, each particle changes its position according to the following eqn. (10b).
11. With the positions calculate the generation output of all the units using eqn. (13) and enforce the P_i limits.
12. Calculate transmission losses using B-coefficient equation and compute the error using equation,

$$\varepsilon = \left| \sum_{i=1}^n P_i - P_D - P_{loss} \right| \quad (14)$$

13. New evaluation values are calculated for the new positions of the particles. If the new evaluation value is better than the previous *pbest* values, the current value is set as *pbest*. If the best *pbest* is better than *gbest*, the value is set to be *gbest*.
14. If the number of iterations is not reached maximum or error is greater than pre-specified value (tolerance), go to step 5.
15. With the *gbest*, compute the optimum values of generation using the eqn. (13) and enforce the P_i limits.
16. Calculate the total fuel cost, total emission release, emission cost, transmission loss etc. Print the result.

RESULTS

The effectiveness of the proposed method is tested with three generating units. A Binary coded Genetic Algorithm (GA) and proposed PSO method are applied to solve the problem. At each sample system, under the same evaluation function and individual definition, 50 trials were performed using the GA and PSO methods and best result is tabulated.

A reasonable loss coefficients matrix of power system network was employed to draw the transmission line loss and satisfy the transmission capacity constraints. The program is written in MATLAB software package and executed on a P-IV personal computer @1.5 GHz.

Although the PSO method seems to be sensitive to the tuning of some weights or parameters, according to the experiences of many experiments, the following PSO and GA parameters can be used.

GA method

- Number of bits = 12
- Population size = 60
- Number of iterations = 250
- Elitism probability = 0.15
- Cross over probability = 0.7
- Mutation probability = 0.01

The equal system incremental cost (λ) is used as the encoded parameter in the string.



PSO method

- Number of particles = 10,
- Inertia weight parameter w is set by (8) where $w_{max} = 0.9$ and $w_{min} = 0.4$
- Learning factor, $c1 = 2.02$ and $c2 = 2.02$
- Maximum number of iterations = 250

Three- unit system

The generator cost coefficients, emission coefficients and generation limits of three units system are taken from [10]. Transmission loss for this system is calculated using B- coefficient matrix and is given. ELD solution for the three-unit system is solved using evolutionary algorithms such as GA and PSO. Tables 2 and 3 summarize all the results of for various load demands. Comparison of total cost obtained from GA and PSO in combined economic and emission dispatch for load of 700MW is shown in Figure-2.

Result analysis

As seen in tabulated results, the PSO method can obtain lower fuel cost and emission release than the GA method, thus resulting in the higher quality solution. This

is, because the PSO method does not perform the selection and crossover operations in evolutionary processes, it can save some computation time compared with the GA method, thus these data are evidence of the superior properties of the PSO method.

CONCLUSIONS

Algorithms have been developed for the determination of the global or near-global optimal solution for the Combined Economic and Emission Dispatch (CEED) problem. The solution algorithms have been tested for test system with three generating units. The PSO approach has demonstrated an ability to provide accurate and feasible solutions within reasonable computation time.

Scope for further work

This paper gives solution of economic dispatch problem for thermal units only. This can be used as a sub-problem for hydrothermal scheduling. It will give complete solution of economic dispatch problem. In this paper it is assumed that the unit commitment is known priori. So unit commitment can be done using PSO technique, and can be integrated to this part.

Table-1. Cost and emission coefficients of 3- unit system.

Unit	a_i	b_i	c_i	α_i	β_i	γ_i
1	0.03546	38.30553	1243.5311	0.00683	-0.54 551	40.26690
2	0.02111	36.32782	1658.5696	0.00461	-0.51 160	42.89553
3	0.01799	38.27041	1356.6592	0.00461	-0.51 160	42.89553

The Loss Coefficient Matrix of 3- Unit System

$$B_{ij} = \begin{matrix} 0.000071 & 0.000030 & 0.000025 \\ 0.000030 & 0.000069 & 0.000032 \\ 0.000025 & 0.000032 & 0.000080 \end{matrix}$$




Figure-2. Comparison of total cost obtained from Conventional method, GA and PSO for a 3- unit system (considering only power limits).

**Table-2.** Combined economic and emission dispatch- 3 unit system (considering only power limits).

Sl. No.	Power Demand (MW)	Method	P ₁ (MW)	P ₂ (MW)	P ₃ (MW)	F _{loss} (MW)	Fuel Cost (Rs/hr)	Emission Release (Kg/hr)	Price Penalty Factor (Rs/Kg)	Total cost (Rs/hr)	Execution Time (sec.)
1	350	GA	89.5681	134.552	131.587	5.64955	18591.8	159.118	43.3001	25481.6	0.109
		PSO	89.557	134.53	131.561	5.64762	18589.2	159.076	43.3001	25477.2	0.281
2	400	GA	102.617	153.825	151.011	7.41324	20840.1	200.256	43.5598	29563.2	0.282
		PSO	102.612	153.809	150.991	7.41173	20838.3	200.221	43.5598	29559.9	0.235
3	450	GA	115.761	173.203	170.52	9.42778	23142.6	250.929	43.8195	34138.2	0.157
		PSO	115.754	173.18	170.491	9.42528	23140	250.866	43.8195	34132.8	0.25
4	500	GA	128.997	192.683	190.11	11.6964	25499.4	311.273	44.0792	39220.1	0.172
		PSO	128.984	192.645	190.063	11.6919	25495	311.15	44.0792	39210.2	0.156
5	550	GA	142.294	212.217	209.733	14.2167	27905.4	381.258	44.3389	44810	0.235
		PSO	142.302	212.204	209.709	14.2151	27904.1	381.216	44.3389	44806.8	0.125
6	600	GA	155.714	231.895	229.479	17.0039	30372.3	461.352	44.5985	50948	0.203
		PSO	155.711	231.859	229.428	16.9987	30368.2	461.207	44.5985	50937.3	0.234
7	650	GA	169.191	251.62	249.25	20.0477	32888.6	551.299	44.8582	57618.9	0.469
		PSO	169.212	251.612	249.223	20.0466	32888	551.274	44.8582	57617.2	0.188
8	700	GA	182.783	271.478	269.132	23.365	35466	651.631	45.1179	64866.2	0.219
		PSO	182.806	271.463	269.093	23.3626	35464.6	651.569	45.1179	64862	0.203
9	750	GA	196.465	291.43	289.086	26.9534	38099.9	762.314	45.3776	72691.9	0.203
		PSO	196.496	291.414	289.041	26.9508	38098.6	762.249	45.3776	72687.6	0.297

Table-3. Comparison of total fuel cost and emission release obtained from Pure ED, Pure emission dispatch and CEED for a 3- unit system (considering only P limits).

Sl. No.	Power Demand (MW)	Method	Fuel Cost (Rs/hr)			Emission Release (Kg/hr)		
			Pure ED	Pure emission dispatch	CEED	Pure ED	Pure emission dispatch	CEED
1	350	GA	18566	18596.3	18591.8	164.395	159.026	159.118
		PSO	18564.6	18595.4	18589.2	164.359	159.01	159.076
2	400	GA	20828.5	20846.6	20840.1	206.056	200.191	200.256
		PSO	20812.4	20844.8	20838.3	205.716	200.154	200.221
3	450	GA	23127.1	23149.7	23142.6	257.001	250.867	250.929
		PSO	23112.5	23146.8	23140	256.628	250.797	250.866
4	500	GA	25469.3	25505.1	25499.4	317.362	311.159	311.273
		PSO	25465.6	25502.2	25495	317.233	311.079	311.15
5	550	GA	27875.4	27912.2	27905.4	387.796	381.155	381.258
		PSO	27872.6	27911.8	27904.1	387.673	381.141	381.216
6	600	GA	30335	30378.9	30372.3	468.168	461.216	461.352
		PSO	30334.2	30376.4	30368.2	468.092	461.13	461.207
7	650	GA	32852.7	32899.9	32888.6	558.751	551.311	551.299
		PSO	32851.3	32896.8	32888	558.639	551.194	551.274
8	700	GA	35426.8	35476	35466	659.623	651.573	651.631
		PSO	35424.7	35474	35464.6	659.467	651.487	651.569
9	750	GA	38058.9	38110.1	38099.9	770.977	762.229	762.314
		PSO	38055.4	38108.7	38098.6	770.732	762.164	762.249

REFERENCES

- [1] I. J. Nagrat, P. Kothari. 1989. Modern Power System Analysis. Tata McGraw-Hill Publishing Company Ltd., New Delhi, India.
- [2] E. H. Chowdhury, Saifur Rahman. 1990. A Review of Recent Advances in Economic Dispatch. IEEE Trans. on Power Syst. 5(Nov.): 1248-1259.
- [3] Palanichamy C., Srikrishna K. 1991. Economic thermal power dispatch with emission constraint. J. Institution of Engineers (India). 72(April): 11-18.
- [4] A. A. El-Keib, H. Ma, J. L. Hart. 1994. Economic Dispatch in View of the Clean Air Act of 1990. IEEE Trans. Power Syst. 9(2): 972-978.
- [5] J. Kennedy and R. Eberhart. 1995. Particle swarm optimization. In: Proc. IEEE Int. Conf. Neural Networks (ICNN'95). Vol. IV, Perth, Australia, pp. 1942-1948.
- [6] Gerald B. Sheble Kristin. 1995. Brittig Refined Genetic Algorithm-Economic Dispatch Example. IEEE Trans. on Power Syst. 10(1): 117-124.
- [7] P. Venkatesh, R. Gnanadass and Narayana Prasad. 2003. Padhy Comparison and application of evolutionary Programming techniques to combined



www.arpnjournals.com

economic Emission dispatch with line flow constraints. IEEE Trans. Power Syst. 18(2): 688-697.

- [8] S. Rajesekaran. and G.A. Vijayalakshmi Pai. 2003. Neural Networks, Fuzzy Logic, and Genetic Algorithms Synthesis and Applications. Prentice Hall Pvt. Ltd.
- [9] A. Immanuel Selva Kumar, K. Dhanushkodi, J. Jaya Kumar, C. Kumar. 2003. Charlie Paul Particle Swarm Optimization Solution to Emission and Economic Dispatch Problem. IEEE TENCON.
- [10] M. Sudhakaran, S. M. R. Slochanal, R Sreeram, N Chandrasekhar. 2004. Application of Refined Genetic Algorithm to Combined Economic and Emission Dispatch. IE (I) Journal-EL. 85(Sept.): 115-119.